

RECEIVED Parcel No. 03-03-22

Application No. A17-02

OCT 27 2016

TOWN AND VILLAGE OF LUDLOW, VERMONT
Application for Access Permit

MUNICIPAL OFFICE
M
N

Residential		Agricultural		Residential Development
Commercial		Industrial		Other

A plot plan must be attached to this application when submitted.

OWNER: 24 FOX LANE, LLC

MAILING ADDRESS: 5 Northfield Road
Wallingford, CT 06492

The Applicant requests a permit to construct an access in accordance with the Town/Village of Ludlow's Highway Standards to serve the property known as 24 Fox Lane, located on the Eastern side of Town/Village Highway No. 103 (the local road name being Vermont Route #103). The proposed access will be located approximately 280 (Feet/Miles) from the intersection of this road with Vermont Route #103

The Applicant agrees to maintain said access, and to adhere to the directions, restrictions, and conditions forming a part of this permit.

[Signature] 10/26/2016
Applicant/Agent Date

ACCESS PERMIT

This permit is issued in accordance with 19 V.S.A. 43, relative to all highways within the control and jurisdiction of the Town/Village of Ludlow, Vermont. The issuance of this permit does not release the Applicant from any requirements of State statutes, local ordinances, or rules and regulations administered by other governmental agencies.

This permit shall be effective upon compliance with such requirements are applicable, and shall continue in effect for as long as the land use continues. Any change from the proposed land use will require a new permit.

This permit is issued subject to the directions, restrictions, and conditions contained herein and any attachments hereto, and covers only the work described in this application, and then only when the work is performed as directed.

Violations shall be subject to the penalties set forth in Title 19, Section 43, of the Vermont Statutes Annotated, with fines of not less than \$100.00, nor more than \$10,000.00, for each violation.

Directions, Restrictions, and Conditions

Access already exists, Existing Culvert
Must be Up Graded to 40" of 15" HDPE Culvert
Installed to Town Sides with Headers installed
on both Ends.

[Signature] 10-27-16 [Signature] 10-27-2016
Road Foreman Date Municipal Manager Date

RECEIVED
JAN 09 2017
By _____